

7.4.5 Efficiency Standards for Commercial Unit Heaters

Unit heaters manufactured on or after August 8, 2008 must:

- Be equipped with an intermittent ignition device and
- Have power venting or an automatic flue damper.
- For unit heaters where combustion air is drawn from conditioned space, an automatic vent damper may be used as an alternative to an automatic flue damper.

Source(s): Title 10, Code of Federal Regulations, Part 431 - Energy Efficiency Program for Certain Commercial and Industrial Equipment, Subpart N - Unit Heaters. January 1, 2010.